

# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6081734

Paisley School District  
 PO Box 97  
 Paisley, OR 97636  
 13294

Project: General

Date Reported: 08/28/16  
 Date Received: 08/17/16 12:15  
 Sampled By: Ruth Robinson

Client Contact: Attn: Ruth Robinson

**Method: EPA 200.8**

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6081734-01	Sample Location: Debbie's Room									
Lead		1030	0.015	mg/L	0.002	0.02	08/12/16 07:23	08/23/16	DJP	
Copper			0.111	mg/L	0.010	1.3	08/12/16 07:23	08/23/16	DJP	
6081734-02	Sample Location: 505 Mill St. Kitchen									
Lead		1030	0.005	mg/L	0.002	0.02	08/12/16 07:15	08/23/16	DJP	
Copper			0.030	mg/L	0.010	1.3	08/12/16 07:15	08/23/16	DJP	
6081734-03	Sample Location: Dorm Kitchen									
Lead		1030	ND	mg/L	0.002	0.02	08/12/16 07:12	08/23/16	DJP	
Copper			0.054	mg/L	0.010	1.3	08/12/16 07:12	08/23/16	DJP	
6081734-04	Sample Location: Dorm Pantry									
Lead		1030	ND	mg/L	0.002	0.02	08/12/16 07:12	08/23/16	DJP	
Copper			0.097	mg/L	0.010	1.3	08/12/16 07:12	08/23/16	DJP	
6081734-05	Sample Location: K-3 Room									
Lead		1030	0.007	mg/L	0.002	0.02	08/12/16 07:19	08/23/16	DJP	
Copper			0.012	mg/L	0.010	1.3	08/12/16 07:19	08/23/16	DJP	
6081734-06	Sample Location: 5-6 Room									
Lead		1030	0.008	mg/L	0.002	0.02	08/12/16 07:20	08/23/16	DJP	
Copper			ND	mg/L	0.010	1.3	08/12/16 07:20	08/23/16	DJP	
6081734-07	Sample Location: V-Tel Room									
Lead		1030	0.005	mg/L	0.002	0.02	08/12/16 07:22	08/23/16	DJP	
Copper			0.014	mg/L	0.010	1.3	08/12/16 07:22	08/23/16	DJP	
6081734-08	Sample Location: Concession Gym									
Lead		1030	0.004	mg/L	0.002	0.02	08/12/16 07:38	08/23/16	DJP	
Copper			0.117	mg/L	0.010	1.3	08/12/16 07:38	08/23/16	DJP	
6081734-09	Sample Location: Gym Drinking Fountain									

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



# UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
 Myrtle Creek, Oregon 97457  
 (541) 863-5201 Fax: (541) 863-6199  
 E-mail: Lab@URCmail.net  
 Internet: http://ChemLab.cc  
 ORELAP ID# OR100031

## ANALYSIS REPORT

URC # 6081734

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
Lead		1030	0.006	mg/L	0.002	0.02	08/12/16 07:40	08/23/16	DJP	
Copper			0.029	mg/L	0.010	1.3	08/12/16 07:40	08/23/16	DJP	
6081734-10	Sample Location: SW Faucet									
Lead		1030	0.002	mg/L	0.002	0.02	08/12/16 07:32	08/23/16	DJP	
Copper			ND	mg/L	0.010	1.3	08/12/16 07:32	08/23/16	DJP	
6081734-11	Sample Location: Main Floor Drinking Fountain									
Lead		1030	0.005	mg/L	0.002	0.02	08/12/16 07:55	08/23/16	DJP	
Copper			ND	mg/L	0.010	1.3	08/12/16 07:55	08/23/16	DJP	
6081734-12	Sample Location: Art Room									
Lead		1030	0.002	mg/L	0.002	0.02	08/12/16 07:52	08/23/16	DJP	
Copper			0.044	mg/L	0.010	1.3	08/12/16 07:52	08/23/16	DJP	
6081734-13	Sample Location: Health Room									
Lead		1030	0.024	mg/L	0.002	0.02	08/12/16 08:00	08/24/16	DJP	CON-1
Copper			0.054	mg/L	0.010	1.3	08/12/16 08:00	08/24/16	DJP	
6081734-14	Sample Location: Math/Sci Lab									
Lead		1030	0.005	mg/L	0.002	0.02	08/12/16 07:59	08/23/16	DJP	
Copper			0.046	mg/L	0.010	1.3	08/12/16 07:59	08/23/16	DJP	
6081734-15	Sample Location: Library									
Lead		1030	0.010	mg/L	0.002	0.02	08/12/16 07:57	08/23/16	DJP	
Copper			0.046	mg/L	0.010	1.3	08/12/16 07:57	08/23/16	DJP	
6081734-16	Sample Location: Office									
Lead		1030	0.003	mg/L	0.002	0.02	08/12/16 07:46	08/23/16	DJP	
Copper			0.031	mg/L	0.010	1.3	08/12/16 07:46	08/23/16	DJP	
6081734-17	Sample Location: Cafe DW Sink									
Lead		1030	0.006	mg/L	0.002	0.02	08/12/16 07:34	08/23/16	DJP	
Copper			0.264	mg/L	0.010	1.3	08/12/16 07:34	08/23/16	DJP	
6081734-18	Sample Location: Cafe HW Sink									
Lead		1030	ND	mg/L	0.002	0.02	08/12/16 07:33	08/23/16	DJP	
Copper			0.114	mg/L	0.010	1.3	08/12/16 07:33	08/23/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



## UMPQUA Research Company

626 NE Division St. - P.O. Box 609  
Myrtle Creek, Oregon 97457  
(541) 863-5201 Fax: (541) 863-6199  
E-mail: Lab@URCmail.net  
Internet: <http://ChemLab.cc>  
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6081734

### Qualifiers and Definitions

CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager