

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: http://ChemLab.cc
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101107

*Re-Tests
(same health room
Fixture. EPA Guidelines)*

Paisley School District	Project: General	Date Reported: 10/18/16
PO Box 97	Project #: Retest Faucet in Health Room Paisley	Date Received: 10/11/16 10:50
Paisley, OR 97636	SD	Sampled By: Ruth Robinson
13387	Client Contact: Attn: Ruth Robinson	

Method: EPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
6101107-01	Sample Location: Health Room #1									
Lead		1030	0.007	mg/L	0.002	0.02	10/10/16 06:43	10/12/16	DJP	
Copper			0.035	mg/L	0.010	1.3	10/10/16 06:43	10/12/16	DJP	
6101107-02	Sample Location: Health Room #2									
Lead		1030	0.008	mg/L	0.002	0.02	10/10/16 06:46	10/12/16	DJP	
Copper			ND	mg/L	0.010	1.3	10/10/16 06:46	10/12/16	DJP	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 6101107

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Tom Williams, Laboratory Manager